




Reference No.: (OTHR)485-AP/485/2026/7

URA Weekly Water Quality Report - Week 5, July 2026

		Reference Units	6.5 - 8.5	<1000 µS/cm	<1 NTU	<500 mg/L	0 CFU/100 mL	0 CFU/100 mL
Location	Prepared by	Checked by	pH	Conductivity	Turbidity	TDS	Total Coliform	E-Coli
Male'			7.19	629	0.045	328	0	0
Hulhumale'			6.61	532	0.052	264	0	0
Villimale'			7.04	611	0.049	307	0	0
K. Huraa			6.92	421	0.126	217	0	0

Approved by

A. A. A. A.

HOD / Director

Service Quality and Assurance Section



Utility Regulatory Authority
Kaasinjee Magu, Henvairu, Male', 20044,
Male', Republic of Maldives.

20044